

REFERENCES:

- 1 ASHRAE HANDBOOK - APPLICATION 2011 - CHAPTER 53, FIRE AND SMOKE MANAGEMENT
- 2 NFPA 92 - 2012 - STANDARD FOR SMOKE CONTROL SYSTEMS
- 3 Chemical Industries Association Guidance for location and design of occupied buildings on chemical manufacturing sites

TABLE CALCULATING TOTAL BUILDING LEAKAGE AREA

	QTY.	SIZE SQ. FT.	TOTAL AREA SQ. FT.	LEAKAGE RATIO*	DOOR/WINDOW LEAKAGE AREA** SQ. FT.	LEAKAGE AREA SQ. FT.
BUILDING FLOOR	1		17250	0.000052		0.897
BUILDING WALL	1		8977.5	0.00017		1.526175
BUILDING ROOF	1		17250	0.00005		0.8625
SINGLE DOORS ON ENVELOPE	4	21			0.21	0.84
DOUBLE DOORS ON ENVELOPE	4	42			0.31	1.24
TOTAL LEAKAGE AREA						5.365675

*NFPA 92 - 2012 - TABLE A.4.4.4.3

** ASHRAE HANDBOOK - APPLICATION 2011 - CHAPTER 53 - PAGE 53.6

CALCULATING PRESSURIZATION AIRFLOW:

- Q VOLUMETRIC AORFLOW RATE, CFM
- A FLOW AREA (LEAKAGE AREA), SQ. FT.
- p PRESSURE DIFFERENCE ACROSS FLOW PATH, IN. OF W.C.
0.2" w.c (Chemical Industries Association Guidance for location and design of occupied buildings on chemical manufacturing sites - page 35, section A4.17

$$Q = 2610 \cdot \cdot \cdot \cdot (\cdot \cdot)$$

AHSRAE HANDBOOK - APPLICATIONS 2011 - CHAPTER 53, EQUATION 9

AIRFLOW (Q) 6,262.96 CFM

FACTOR OF SAFETY 0.05

DESIGN AIRFLOW 6,576.11 CFM